

Testing. Advising. Assuring.

WF Report No. 190467
Page 1 of 2
29th January 2010

Mr B. Peach
Firestopit Limited
Westminster Industrial Estate
Tamworth Road
Measham
DE12 7DS

Review of Assessment Report Referenced WFRC No. 144508/A

1 Introduction

The assessment report referenced WFRC No. 144508/A presents of the fire resistance performance of 'Pyrocoustic' linear gap sealing systems when used in various supporting constructions, if tested utilising the general principles of BS 476: Part 20: 1987, in conjunction with additional guidelines from the draft European Standard prEN 1366-4..

The appraisal report concludes that 'Pyrocoustic' linear gap seals, should provide up to 300 minutes integrity and insulation performance depending upon dimensions and supporting construction (as shown in the Annex to this report), if tested utilising the general principles of BS 476: Part 20: 1987, in conjunction with additional guidelines from the draft European Standard prEN 1366-4.

2 Confirmation of Specification

It has been confirmed by Firestopit Limited that there have been no changes to the specification of the constructions considered in the original appraisal referenced WFRC No. 144508/A.

3 Conclusions

The data used for the original appraisal has been re-examined and found to be satisfactory.

The procedures adopted for the original assessment have also been re-examined and are similar to those currently in use.

Therefore, with respect to the assessment of performance given in WFRC No. 144508/A, the contents should remain valid until 1st February 2015.

4 Validity

This review is based on information used to formulate the original test report. No other information or data has been submitted by Firestopit Limited, which could affect this review.

The original appraisal report was performed in accordance with the principles of the UK Fire Test Study Group Resolution 82: 2001 and this review has therefore been conducted using these principles.

Performed by:



C Johnson

Principal Certification Engineer
Exova warringtonfire

Reviewed By:



D Hankinson

Principal Certification Engineer
Exova warringtonfire

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.